



Epic Environmental Services, LLC  
1930 Brown Road  
Newfield, NJ 08344

Sample # Q1671  
Sample Received: 4/3/17  
Sampled by: James Eberts (Epic Env)

**Stow Creek Twp. School**  
11 Gum Tree Corner Road, Bridgeton, NJ 08302

## CERTIFICATE OF ANALYSIS

N.J.D.E.P. CERTIFICATION # 06003

Results in mg/(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Time Sampled	FD / FL	Lead ug/L	Date Analyzed	Time Analyzed
Q1671-2	02 STC-01-KO-KITCH	3/30/2017	5:43	FD	<2	4/4/2017	14:02
Q1671-4	04 STC-02-NS-NURSE	3/30/2017	5:45	FD	<2	4/4/2017	14:06

Note: FD represents First Draw and FL represents Flushed sample

Latish Menghani  
Laboratory Director

722 S. Brewster Rd., Ste. B1, Vineland, NJ 08361  
 Office: (856) 692-6800 • Cell: (856) 297-3063 • Fax: (856) 692-3700

**CHAIN OF CUSTODY**  
 Page 1 of 1

Client/Account No. Epic Environmental Services, LLC

Address 1930 Brown Road

City/State/Zip Newfield, NJ 08344

Phone/Fax 856-205-1077 / 856-2052-0413

Client Contact Jim Eberts

Bill to/Report to (if different)

SAME

Sampling Site Address (if different)

Stow Creek Twp School

11 Gum Tree Corner Rd, Bridgeton, NJ 08302

P.O. No. xxxxxx

VEL Contact

PROJECT Stow Creek Twp School

FIELD ID

STC-EB

STC-01-KO-KITCH

STC-01-KO-KITCH (FLUSH)

STC-02-NS-NURSE

STC-02-NS-NURSE (FLUSH)

End of samples

Collection	Date	Military Time	G		C		M		N		Z	
			A	B	A	B	A	B	A	B	A	B
STC-EB	3/30/17	0546	X		DW							
STC-01-KO-KITCH		0543	X									
STC-01-KO-KITCH (FLUSH)		0543	X									
STC-02-NS-NURSE		0545	X									
STC-02-NS-NURSE (FLUSH)		0546	X									

Lead in Drinking Water

Lab LIMS No: 01671

**LAB USE ONLY:**

Ascorbic/HCl Vials # HCl Vials

Na<sub>2</sub>S<sub>2</sub>O<sub>5</sub> #

Na OH/Zn acetate pH #

HNO<sub>3</sub> pH # *2 prepared by lab*

H<sub>2</sub>SO<sub>4</sub> pH # *4/3/17/1102*

NaOH pH #

Unpreserved #

HCl pH #

Temp control # *OK*

ID # *Weld*

**ANALYSIS REQUESTED**

**MATRIX CODES**

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SD: SOIL

SL: SLUDGE

SOL: NON SOLID

MI: MISCELLANEOUS

X: OTHER

Field pH, Temp (C or F), DO, Cl, S. Cond. etc.

SAMPLED BY: (Name/Company) James Eberts  
 Epic Environmental Svs

Verbal/fax data due: Two Week Results  
 Handcopy due: Two Week Results

Report Format:  Standard  Forms  NI EXCEL  
 Standard + QC  NI Reduced  Disk

Sig: \_\_\_\_\_ Date/Time: \_\_\_\_\_

Field Parameters Analyzed By: \_\_\_\_\_

SAFETY: Please call for pricing and availability on rush (1-14-21 day) turnaround and on all but standard format.

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE. DATE AND MILITARY TIME (24 HOUR CLOCK, I.E. 8 AM IS 0800, 4 PM IS 1600)**

RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME
1. <i>James Eberts</i>	4/3/17	1020	1. <i>NAJIBUDDIN</i>	4/3/17	1020
2. RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME
3. RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME
4. RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME
5. RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME

DELIVERY METHOD:  VELOCITY  CLIENT  UPS  FEDEX  OTHER

Custody Seal Number

**COMMENTS:**

- Analyze ALL "First Draw" samples and Field Blank.
- Analyze corresponding "FLUSH" sample for any first draw sample result OVER 15.5 ppb.
- Email results to jeberts@epiceniviro.com.

Hazardous:  Yes  No